


CERTIFICATE

Certificate holder	SIT S.p.a. Viale dell'Industria 31-33 35129 Padova PD ITALY
Product	Temperature control and limiting devices for heat generating systems
Type, Model	610 AC3 - 650 Delta - 600 AC2
Testing basis	DIN EN 14597:2015-02 Certification scheme Temperature control and limiting devices for heat generating systems (2009-01)
Mark of conformity	
Registration No.	STB1135S
Valid until	2023-02-28
Nutzungsrecht	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

ANNEX

Page 1 of 1

Certificate

STB1135S dated 2018-04-10

Technical Data

Setpoint value ranges / limit value ranges:

610 AC3 94 °C - 12 K

610 AC3 100 °C - 12 K

600 AC2 98 °C - 12 K

650 Delta: 93 °C - 12 K

See technical data sheet to the above mentioned registration number
at www.dincertco.tuv.com

**Testing laboratory/
Inspection body**

TÜV Rheinland Industrie
Service GmbH
51101 Köln
GERMANY

Test report(s)

T101 2008 T2 dated 2008-02-11
GA 11 2010 A7 dated 2010-02-19
21215416 dated 2010-11-17
21218754 dated 2012-01-31
21220772 dated 2012-12-03
T 101 2013 V4 dated 2013-10-08
21226519 dated 2014-11-17
21229240 dated 2015-11-23
T 101 2016 A5 dated 2016-11-21
T 101 2017 A6 dated 2017-11-16
968/FSP 1573.00/18 dated 2018-02-22

