

IAPMO R&T OCEANA

1040 Dandenong Road, Carnegie, VIC 3163 AUSTRALIA



IAPMO R&T Oceana is a product certification body which inspects and arranges for the independent laboratory testing of samples taken from the manufacturer's stock or from the market or a combination of both, to verify compliance of the requirements of applicable Standards and Specifications. This activity is coupled with periodic surveillance of the certified product taken from the market place or the manufacturer's factory. This certification is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO R&T Oceana of the product acceptance by Authorities Having Jurisdiction.

GASMARK CERTIFICATE

Component

IAPMO R&T Oceana hereby grants to:

SIT Gas Controls Pty Ltd

A.B.N.: 51 006 090 357

8 Pickering Road, Mulgrave VIC 3170, AUSTRALIA

the right to use the GasMark in accordance with IAPMO R&T Oceana Pty Ltd 'Mark Rules' on the product as described in the attached GasMark Schedule. The Certificate is granted subject to IAPMO R&T Oceana Pty Ltd 'Governance Rules'.

Evaluated to:

AS 4624 "Combination controls for gas"

Manufactured by:

Refer to Certificate Holder

Certificate No.: GMK10239

Certified Date: 16 September 2015

Issue Date: 16 September 2015

Expiry Date: 15 September 2020

Chief Executive Officer of the IAPMO Group

This GasMark certification is for the period indicated herein and is void after the date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of IAPMO R&T Oceana, or any evidence of non-compliance with applicable Standards, Specifications or of inferior workmanship, may be deemed sufficient cause for revocation of this certification. Reproduction of or reference to this certificate for advertising purposes may be made only by specific written permission of IAPMO R&T Oceana. Any alteration of this certificate could be grounds for revocation of this certification.



GASMARK SCHEDULE



Certificate Holder: SIT Gas Controls Pty Ltd
 Address: 8 Pickering Road
 Mulgrave VIC 3170
 Australia
 A.B.N.: 51 006 090 357

Certificate No.: GMK10239
 Issue Date: 16-Sep-15
 Expiry Date: 15-Sep-20
 First Certified: 16-Sep-15
 Standard/s: AS 4624—2005

Combination controls for gas

Manufacturer: Refer to Certificate Holder

Std/Spec: AS 4624—2005

No.: GMK10239

Distributor	Brand Name	Model ID	Product Description	Classification	Pressure	Temperature	Variations	Inlet/Outlet
Refer to Certificate Holder	SIT	0.880.00x	Proflame On/Off combination control	Regulator Class 4; Grade 20; SSOV Class 3	3.5 kPa	0°C to 80°C	Refer Certificate Holder	3/8 NPT
Refer to Certificate Holder	SIT	0.885.00x	Proflame Modulating combination control	Regulator Class 4; Grade 20; SSOV Class 3	3.5 kPa	0°C to 80°C	Refer Certificate Holder	3/8 NPT
Refer to Certificate Holder	SIT	0.886.00x	Proflame Hi/Lowcombination control	Regulator Class 4; Grade 20; SSOV Class 3	3.5 kPa	0°C to 80°C	Refer Certificate Holder	3/8 NPT

END RECORD

END RECORD

Russ Channy

Chief Executive Officer of the IAPMO Group